

# AWTA TEXTILE TESTING

## Report of Testing

**We hereby declare that the item described below has been tested by AWTA Textile Testing to AS 3837:1998 "Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter" and obtained the following classification when assessed in accordance with the relevant clauses of the Building Code of Australia.**

<b>Group Number</b> (in accordance with Specification A2.4 of the Building Code of Australia)	1
<b>Average Specific extinction area</b> (As per Specification C1.10a 3 (c) of the Building Code of Australia)	0

**The full details of the tests, the results, and any special conditions are given in the Test Report(s) listed**


No.	Dated
7-530711-CV	14/9/2004

**Description of item tested:**

Armalon NG  
White homogeneous calendered vinyl flooring product

**Submitted by:**

Armstrong World Industries  
29-39 Mills Road  
Braeside VIC 3195

Authorised by:  Title: **Division Manager** Date: **16 November 2004**